

SIZE	45x45		
PRODUCT	PORCELAIN. GROUP Bia		
REFERENCE	BALANEE ANTRACITA		
DESCRIPTION OF TEST	TEST VALUE	alaplana. CERÁMICA	TEST STANDARD
WATER ABSORPTION	AA < 0,5%	Pass	UNE-EN-ISO 10545-3
BREAKING STRENGTH	> 1300 N	Pass	UNE-EN-ISO 10545-4
MODULUS OF RUPTURE	> 35 MPa	Pass	UNE-EN-ISO 10545-4
RESISTANCE TO SURFACE ABRASION	Class & Number of Revolutions	PEI III	UNE-EN-ISO 10545-7
CRAZING RESISTANCE	Demanded	Pass	UNE-EN-ISO 10545-11
FROST RESISTANCE	Available Method	Pass	UNE-EN-ISO 10545-12
CHEMICAL RESISTANCE (Cleaning & Swimmingpool Products) (Acid & Alkaline Low Concentration) (Acid & Alkaline High Concentration)	Minimum GB	Pass	UNE-EN-ISO 10545-13
RESISTANCE TO STAINS	Minimum Clase 3	Pass	UNE-EN-ISO 10545-14
SLIP RESISTANCE	Available Method	Clase 1	UNE-ENV 12633:2003
RESISTANCE TO DEEP ABRASION	Minimum 3	Pass	EN 101