

Installation Guide

DEVIreg[™] 330 (+60 to +160°C)

Electronic Thermostat



DEVIreg[™] 330 (+60 to +160°C) **DEVI**°//

	Table of Contents	
1	Introduction	2
2	Mounting Instructions	(
3	Warranty	7
4	Disposal Instruction	7
1	Introduction	

DEVIreg™ 330 is an electronic thermostat to be installed in electric cabinets with DIN rail attachment. The thermostat must be installed via an all-pole disconnection switch. Either a wire sensor or an external air sensor must be used to measure and control the desired temperature.

The thermostat has a button to adjust the temperature setting, with a scale from +60° to +160°C. An LED indicator shows standby periods (green light) and heating periods (red light).

More information on this product can also be found at: devireg.devi.com



1.1 Technical Specifications

Operation voltage	220-240V~, 50Hz
Standby power consumption	Max 0.25W
Relay:	
Resistive load Inductive load	Max 16A / 3680W @ 230V cos φ= 0.3 max1A
Sensing units	NTC 16.7 kOhm at 100°C
Sensing values:	
0°C 25°C 50°C	42kOhm 15kOhm 6kOhm
Hysteresis	± 0.4°C
Ambient temperature	10°C to +50°C
Lowering in economy periods	-5°C
Hysteresis range	± 0.75°C
Temperature range	+60 to +160°C
Cable specification max	1x4mm ² or 2x2,5mm ²
Ball pressure temperature	75°C
Pollution degree	2 (domestic use)
Туре	1C
Storage temperature	-20°C to +65°C

DEVIreg[™] 330 (+60 to +160°C) **DEVI**°//

IP class	20	
Protection class	Class II - 🗆	
Dimensions	86 x 36 x 58mm	
Weight	83g	

The product complies with the EN/IEC Standard "Automatic electrical controls for household and similar use":

- EN/IEC 60730-1 (general)
- EN/IEC 60730-2-9 (thermostat)

1.2 Safety Instructions

Make sure the mains supply to the thermostat is turned off before installation.

Please also note the following:

- The installation of the thermostat must be done by an authorized and qualified installer according to local regulations.
- The thermostat must be connected to a power supply via an all-pole disconnection switch.
- The sensor is to be considered as live voltage. Have this in mind if the sensor must be extended.
- Always connect the thermostat to continuous power supply.
- Do not expose the thermostat to moisture, water, dust, and excessive heat.


2 Mounting Instructions

Please observe the following placement guidelines:

- Install the thermostat in an electric cabinet with DIN rail attachment or a separate DIN attachment according to local regulation on IP classes.
- Do not place the thermostat in a way that it will be exposed to direct sunlight.

Follow the steps below to mount the thermostat:

- 1. Click the thermostat on to the DIN rail attachment.
- Connect the thermostat according to the connection diagram.



DEVIreg[™] 330 (+60 to +160°C) **DEVI***///

The screen of the heating cable must be connected to the earth conductor of the power supply cable by using a separate connector.

Note: When you use the wire sensor for floor heating, always install the sensor in a conduit.

3. Turn on the power supply.

3 Warranty



4 Disposal Instruction



DEVI[™] DEVIreg[™] 330 (+60 to +160°C)



DEVI[™] DEVIreg[™] 330 (+60 to +160°C)




Danfoss A/S Electric Heating Systems Ulvehavevej 61 7100 Vejle Denmark Phone: +45 7488 8500 Fax: +45 7488 8501

E-mail: EH@DEVI.com

www.DEVI.com

Darfors can accept no responsibility for possible errors in catalogues, brochures and other printed material. Darfors reserves the right or later its products without notice. This also applies to products a livent or notice. This also applies to products a livent or notice. This also applies to products a livent or notice. This also applies to product a livent or notice and the subsequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies, DEVI and the DEVI logotype are trademarks of Darfors AS-AI rights reserved.

DEVIreg 330 +60<>+160° 140F1073



+60 to +160°C 220-240V~ ~zH09-05

Designed in Denmark for Danfoss A/S











