

**Head Office**  
Forskningsveien 3b  
P.O.Box 123 Blindern  
NO-0314 OSLO  
Tel. +47 22 98 55 55  
Fax +47 22 69 94 38

**Local Department**  
Høgskoleringen 7b  
NO-7491 TRONDHEIM  
Tel. +47 73 59 33 80  
Fax +47 73 59 33 80

E-mail: firmapost@byggforsk.no  
Internet: www.byggforsk.no  
Registration No. NO 943 813 381 VAT

Client Ifö Sanitär AB
Client's address P.O. Box 140 SE-295 22 Bromölla Sweden
Client's contact-person Stefan Danielsson

Project/archive no. O6870/376	Date 09.06.06	Rev. date	No. of pages 10	Appendixes	Classification Restricted	Author(s) Bjørn-Roar Krog
Project leader Bjørn-Roar Krog	Sign. BRK	Responsible manager Mads Mysen	Sign. HAM	Quality assurance Lars-Erik Fiskum	Sign. Lef	

## Assignment Report

# Testing of WC from Ifö Sanitär AB, type Ifö Sign no. 6860. Test method NS-EN 997.

**Water and Sanitation  
laboratory**

The test results are valid  
exclusively for the tested  
objects.

<b>Summary</b>			
Norwegian Building Research Institute (NBI) has on behalf of Ifö Sanitär AB carried out testing of water closet with S-trap, type Ifö Sign no. 6860.			
The tests have been carried out in accordance with NS-EN 997:2003 "WC pans and WC suites with integral trap". See Table 4.1 for conducted tests.			
The water closet is classified as Class 1 in accordance with NS-EN 997, and the pan is tested using a nominal flush volume of 4 l.			
Result: Passed			
Address of the building			Built (year)
Activity code	Method EN 997	Keywords WC	Filename O6870/376