



CB TEST CERTIFICATE

Ref. Certificate No.

IT-8194

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	IMQ SpA		
Product:	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) with integrated socket-outlet		
Applicant:	GEWISS SPA	VIA A.VOLTA 1 24069 CENATE SOTTO (BG)	Italy
Manufacturer:	GEWISS SPA	VIA A.VOLTA 1 24069 CENATE SOTTO (BG)	Italy
Factory:	GEWISS PORTUGAL, LDA	Zona Industrial 2a Fase, Bustelo 4560-709 PENAFIEL	Portugal
Rating and principal characteristics:	1P+N; 230V; 16A; Type A; I _{Δn} 10-30mA; I _m /I _{Δm} 500A; I _{nc} /I _{Δc} 3000A (see on pages 2 and 4 of Test Report 03SJ00003/00)		
Trade mark (if any):	GEWISS		
Type of Manufacturer's Testing Laboratories used:	SMT		
Model/Type reference:	GW95921, GW95922, GW95923, GW95924 (see on page 4 of Test Report 03SJ00003/00)		
Additional information:	Testing according to EN 61008-1:2004 + A11:2007		
Sample of product tested to be in conformity with IEC:	61008-1(ed.2);am1		
Test Report Ref. No:	03SJ00003/00, 03SJ00003/01, 03SJ00003/02, 03SJ00003/03, 02SJ00012/1, 02SJ00012/2		

This CB Test Certificate is issued by the National Certification Body:

IMQ SpA
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2009-04-09



IMQ