

LICENCE

No. 16744

Issued to:
Applicant:
Schneider Electric Industrie SAS
31, rue Pierre Mendès France, Eybens
38050 GRENOBLE CEDEX 09
France



Licensee:
Schneider Electric NV/SA
Dieweg 3
1180 BRUSSEL
Belgium

Product : isolating switches
Trade name(s) : SCHNEIDER ELECTRIC
Type(s)/model(s) : Series iSW

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 12


SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 13/07/2010


ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	isolating switches
Trade name(s)	:	SCHNEIDER ELECTRIC
Type(s)/Model(s)	:	Series iSW
pattern no(s).	:	1, 2, 3 & 03
rated voltage (Un)	:	250 Vac (1P) and 415 Vac (2P, 3P & 4P)
rated current (In)	:	20 A & 32 A
method of actuating	:	tumbler
method of application	:	semi flush-type, DIN rail
terminals	:	screw-type

Additional information

See Appendix

TESTS

Test requirements

NBN EN 60669-2-4:2005

Test results

The test results are laid down in test report(s) ref. 58182202/00 and 58182201/00 up to 58182201/07


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Silvio Pifas - 13/07/2010

Department Manager,
Product Certification :

Certification Manager :



2010-07-14

FACTORY LOCATION(S)

Schneider Electric NV/SA
Dieweg 3
1180 BRUSSEL
Belgium

Product References:

Base Modules				Ratings	
	Ref	P	Pattern	In (A)	Un (V)
<i>iSW</i>	A9S60120	1	1	20	250
	A9S60220	2	2	20	415
	A9S60320	3	3	20	415
	A9S60420	4	03	20	415
	A9S60132	1	1	32	250
	A9S60232	2	2	32	415
	A9S60332	3	3	32	415
	A9S60432	4	03	32	415
<i>iSW with indicator light</i>	A9S61220	2	2	20	250
	A9S61232	2	2	32	250

