

## **CERTIFICATE**

## No. P10212813





Order No. 155073 Page 1/1 **Product** Timer **Applicant** Schneider Electric Industries SAS 35, rue Joseph Monier, P.O Box 30323 FR 92506 Rueil-Malmaison France Manufacturer Schneider Electric Industries SAS 35, rue Joseph Monier, P.O Box 30323 FR 92506 Rueil-Malmaison France **Factory** Strömfors Electric Oy Ahlströmintie 1 07970 Ruotsinpyhtää Finland ☐ See next page(s) Ratings 230V 50Hz. Load: 10A 230V AC, 10A 24V DC Trade mark Schneider Electric Model / Type Ref. ATC10A Principal characteristics IP44 with protective case type BBV49557, IP20 without protective case type BBV49557. Push-button, Design A, Flush-type, Pillar terminals See next page(s) A sample of the product was tested INST EN 60669-1:1999;A1;A2 and found to be in conformity with EN 60669-2-1:2004;A1;A12 EN 60669-2-3:2006 This certificate documents conformity with the standards shown, and also applies as license for use Validity of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary. Additional information See next page(s)

Date of issue 04-08-2010

Additional model(s)

Gew Clor Hu Signature Geir Hørthe

Certification Department

Nemko ASOffice addressInternetTelephoneFaxP.O. Box 73, BlindernGaustadalléen 30www.nemko.com+47 22 96 03 30+ 47 22 96 05 50N-0314 Oslo, NorwayOsloEnterprise number:NO 974404532

See next page(s)