


Dok.Kod.No:FR.280.01 Yayın Tarihi:01.12.2015 Rev.No:01/15.04.2022	CERAMIC TILES-DETERMINATION OF THE ANTI-SLIP PROPERTIES	HİTİT SERAMİK	
PRODUCT NAME: 10X10 ASSEN SERİSİ		DATE: 30.05.2024	
RELATED STANDARD DIN 51130		RELATED STANDARD DIN 51097	
TEST VALUES		TEST VALUES	
1 st Person average acceptance angle	15,7	1 st Person average acceptance angle	21,7
2ndPerson average acceptance angle	16	2ndPerson average acceptance angle	21,9
3ndPerson average acceptance angle	16,1	3ndPerson average acceptance angle	22,1
AVERAGE TOTAL ACCEPTANCE ANGLE	15,9	AVERAGE TOTAL ACCEPTANCE ANGLE	21,9
RELATED STANDARD DIN 51130		RELATED STANDARD DIN 51097	
☐ :	UNRELATED STANDARD	☐ :	UNRELATED STANDARD
☐ R9:	6° - 10°	☐ A:	≥ 12°
☒ R10:	> 10° - 19°	☒ B:	≥ 18°
☐ R11:	> 19° - 27°	☐ C:	≥ 24°
☐ R12:	> 27° - 35°		
☐ R13:	> 35°		
PERSON IN CHARGE OF TEST AD-SOYAD-İMZA İSMET BUDAK 		RESEARCH AND DEVELOPMENT MANAGER AD-SOYAD-İMZA NAFİZ ÖZDEMİR 	